

# A Decentralized Optimal Load Current Sharing Method for Power Line Loss Minimization in MT-HVDC Systems

Yiqi Liu<sup>\*</sup>, Wenlong Song<sup>†</sup>, Ningning Li<sup>\*\*</sup>, Linqun Bai<sup>\*\*\*</sup>, and Yanchao Ji<sup>\*\*</sup>

<sup>\*,†</sup>College of Mechanical and Electrical Engineering, Northeast Forestry University, Harbin, China

<sup>\*\*</sup>School of Electrical Engineering and Automation, Harbin Institute of Technology, Harbin, China

<sup>\*\*\*</sup>Electrical Engineering and Computer Science Department, University of Tennessee, Knoxville, TN, USA

## Abstract

This paper discusses the elimination of DC voltage deviation and the enhancement of load current sharing accuracy in multi-terminal high voltage direct current (MT-HVDC) systems. In order to minimize the power line losses in different parallel network topologies and to insure the stable operation of systems, a decentralized control method based on a modified droop control is presented in this paper. Averaging the DC output voltage and averaging the output current of two neighboring converters are employed to reduce the congestion of the communication network in a control system, and the decentralized control method is implemented. By minimizing the power loss of the cable, the optimal load current sharing proportion is derived in order to achieve rational current sharing among different converters. The validity of the proposed method using a low bandwidth communication (LBC) network for different topologies is verified. The influence of the parameters of the power cable on the control system stability is analyzed in detail. Finally, transient response simulations and experiments are performed to demonstrate the feasibility of the proposed control strategy for a MT-HVDC system.

**Key words:** Current sharing accuracy, Droop, Multi-terminal high voltage DC (MT-HVDC), Optimization, Power line loss minimization

## I. INTRODUCTION

With the increasing penetration of HVDC grids into modern electric systems, multi-terminal HVDC (MT-HVDC) systems are gaining more attention [1]-[4]. Compared to conventional AC electric grids, DC grids have several advantages, such as the absence of reactive power and harmonics, independence from synchronization, higher efficiency, etc. [5], [6]. In offshore wind farms, considering the capacitive impedance in the sea, transmissions based on AC coupling cannot be used [7], [8]. In this situation, it is

effective to use DC power to transmit the generated power from wind turbines to onshore stations. Since offshore wind farms usually consist of several terminals [9], [10], different network configurations for MT-HVDC systems are formed. There is also an increasing awareness of the current distribution in MT-HVDC systems. A reasonable sharing proportion should be determined to obtain efficient operation from the overall DC system. Several current sharing methods can be found in the existing literature, e.g. master-slave control [11], average current control [12], etc. Considering that different DC terminals may be far from each other, and that the transmission line impedance impacts the stability of control systems, droop control is a suitable current sharing method due to its low communication dependency [13]. However, droop control has two limitations [14]. First, DC output deviation is involved by the droop action. Second, the load current sharing accuracy is degraded when considering the power line loss. It is necessary to solve these problems in order to enhance the performance of droop control. An

Manuscript received Jun. 26, 2015; accepted Jul. 1, 2016

Recommended for publication by Associate Editor Kyeon Hur.

<sup>†</sup>Corresponding Author: [wlsong139@126.com](mailto:wlsong139@126.com)

Tel: +86-15645073688, Northeast Forestry University

<sup>\*</sup>College of Mechanical and Electrical Engineering, Northeast Forestry University, China

<sup>\*\*</sup>School of Electrical Engineering and Automation, Harbin Institute of Technology, China

<sup>\*\*\*</sup>Electrical Engineering and Computer Science Department, University of Tennessee, USA

improved droop control method was proposed in [15]. This method can be used to efficiently compensate the voltage drop and enhance the load distribution accuracy simultaneously. It can also be extended to alleviate the communication stress and to consider both radial and meshed configurations. In [16], the average voltage and average current of the two adjacent converters are selected as control variables, so that the communication traffic can be solved. Although this is suitable for the low voltage level transmission lines of DC microgrids, it is insufficient for MT-HVDC systems since the impact of the transmission line parameters is not comprehensively studied.

In this paper, information on the control variables for each converter is transferred through a LBC network, and the influence of DC cable impedance on the modified droop control system stability is discussed. The optimal current sharing proportional is obtained by power line loss minimization in MT-HVDC systems. Finally, both meshed and radial architectures are studied. Simulation results demonstrate the feasibility of the proposed method based on variable parameters. Section II introduces the MT-HVDC network configurations. This is followed by analyses of the current sharing issues and power line loss minimization. Meanwhile, the impact of MT-HVDC system parameters on stability is discussed in Section III. Section IV presents some simulation and experimental results, and Section V concludes the paper.

## II. ANALYSIS OF MT-HVDC NETWORK CONFIGURATIONS

The converter stations can be connected either in series or in parallel to form a MT-HVDC network configuration. All of the converters need share the same current result when a no series-connected MT-HVDC system was used. At present, the interface converters are parallel-connected with each other. The configurations of the MT-HVDC are generally divided into two groups, namely meshed and radial [17]-[19] networks, as shown in Fig. 1.

### A. Pi-Section Line

For MT-HVDC system DC cable transmission lines, the resistance, inductance, and capacitance are uniformly distributed along the line.

An approximate model of a distributed parameter line is obtained by cascading several identical pi-sections [20], as shown in Fig. 2.

The  $r_L l_L c_L$  elements of land or sub-marine long transmission line sections are calculated by using the following equations [21]:

$$l_L = 0.05 + 0.2 \ln\left(\frac{K \cdot d}{r_c}\right) [\text{mH/km}] \quad (1)$$

where  $K$  is the trefoil or flat formation,  $d$  is the distance between the conductor axes, and  $r_c$  is the conductor radius.




Fig. 1. Network configuration of MT-HVDC system (a) radial (b) meshed.




Fig. 2. Pi-section line model.

$$c_L = \frac{\epsilon_r}{18 \ln(r_0/r_i)} [\mu\text{F/km}] \quad (2)$$

where  $\epsilon_r$  is the relative permittivity of the insulation,  $r_0$  is the external radius of the insulation, and  $r_i$  is the radius of the conductor, including the screen.

Considering the previous analysis and a Thevenin equivalent circuit, equivalent simplified models of the MT-HVDC are shown in Fig. 3 (a) and (b).  $Z_{iL}$  is the equivalent impedance of the DC transmission lines between different converter stations in a radial configuration.  $Z_{L1}$ ,  $Z_{L2}$ ,  $Z_{L3}$  and  $Z_{L3}$  are the equivalent impedances of the DC transmission lines between converters in a meshed configuration.

### B. Radial Configuration

The DC circuit of a MT-HVDC system consists of a large capacitor at the converter station and a DC cable. According to Kirchhoff's law, the following circuit equations can be derived from Fig. 3(a):




Fig. 3. Simplified model of MTDC network configuration. (a) Radial. (b) Meshed.

$$i_{cci} = i_{dci} - C_{dci} \frac{dv_{dci}}{dt} - l_{iL} C_L \frac{dv_L}{dt} \quad (3)$$

$$i_L = \sum_{i=1}^3 i_{cci} \quad (4)$$

$$v_L = i_L R_L \quad (5)$$

Because of the DC side capacitance,  $C_{dci}$  is normally selected to be large enough so that  $C_{dci} \gg C_{Li}$ . For brevity, it is assumed that  $C_{dci} + C_{Li} = C_{dci}$ . The load voltage can be expressed in (6):

$$v_L = v_{dci} - l_{iL} r_L (i_{dci} - C_{dci} \frac{dv_{dci}}{dt}) - l_{iL} l_L \frac{d(i_{dci} - C_{dci} \frac{dv_{dci}}{dt})}{dt} \quad (6)$$

where  $v_{dci}$  and  $i_{dci}$  are the DC side output voltage and current of the interface converter  $\#i$  ( $i=1, 2, 3$ ),  $v_L$  and  $i_L$  are the load voltage and current,  $i_{dci}$  is capacitor branch current,  $i_{cci}$  is the current of the transmission line, and  $r_L$ ,  $l_L$  and  $C_L$  represent the DC cable transmission line impedance parameters. By combining (3)-(6), the relationship between the DC side output current and output voltage for converters  $\#1 \sim \#3$  can be written as:

$$[\mathbf{I}_{dci}] = [\mathbf{Y}_R][\mathbf{V}_{dci}] \quad (7)$$

where the matrix  $\mathbf{Y}_R$  is obtained as an admittance matrix with the radial configuration, which is a  $3 \times 3$  incidence matrix of the directed graph describing the DC network. The full matrix representation is provided in the appendix.

### C. Meshed Configuration

Fig. 3 (b) shows an equivalent circuit of the MT-HVDC system DC side for the meshed configuration. The relationship of the DC side voltage among the converters  $\#1$ ,  $\#2$ ,  $\#3$  and the load is derived as:

$$v_{dc1} - Z_{L1} (i_{dc1} - C_{dc1} \frac{dv_{dc1}}{dt}) = v_{load} \quad (8a)$$

$$v_{dc2} - Z_p (i_{dc2} - C_{dc2} \frac{dv_{dc2}}{dt}) = v_{load} \quad (8b)$$

$$v_{dc3} - Z_{L3} (i_{dc3} - C_{dc3} \frac{dv_{dc3}}{dt}) = v_{load} \quad (8c)$$

where  $Z_p$  is the parallel impedance of the DC cable between converter  $\#2$  and the load, which is equal to:

$$Z_p = (Z_{L1} + Z_{L2}) // (Z_{L3} + Z_{L3}) \quad (9)$$

Based on Fig. 3(b), the load current  $i_{load}$  is obtained as:

$$i_{load} = \sum_{i=1}^3 (i_{dci} - C_{dci} \frac{dv_{dci}}{dt}) - C_{L3L} \frac{dv_{load}}{dt} \quad (10)$$

where  $C_{L3L} = C_{L1} + C_{L3}$ .

Combining (8a), (8b) and (8c), the load voltage is calculated from the product of the load current  $i_L$  and the load resistance  $R_L$ . The DC side output currents of different converters in a meshed-configured MT-HVDC system are shown as:

$$[\mathbf{I}_{dci}] = [\mathbf{Y}_M][\mathbf{V}_{dci}] \quad (11)$$

The matrix  $\mathbf{Y}_M$  is a  $3 \times 3$  bus admittance matrix of the DC network for the meshed configuration, which is similar to  $\mathbf{Y}_R$ . A detail admittance matrix is given in the Appendix.

## III. PROPOSED OPTIMAL METHOD BASED ON DROOP CONTROL

### A. Modified Droop Control Scheme

While relying on the local DC bus voltage signal for the form of the droop control, the voltage-current relation at the traditional droop control [22] can be expressed as:

$$v_{dci} = v_{dc}^* - \frac{m_0}{k_i} i_{dci} \quad (12)$$

where  $v_{dc}^*$  and  $v_{dci}$ , respectively the reference value and the actual value of the output voltage on the DC side at converter  $\#i$  ( $i=1, 2, 3$ ),  $m_0$  is the droop coefficient, and  $k_i$  is the current proportional sharing index.

In order to study the current sharing between different converters in a MT-HVDC system, a decentralized method based on droop control is proposed to solve this problem. According to (12), it can be seen that the given value of the DC side output voltage linearly decreases with an increase of




Fig. 4. Modified droop control diagram.

the DC output current. Since there is no reactive power in the DC side of the MT-HVDC system, only the active current sharing accuracy should be noticed. In general, the consideration of the line impedance is inevitable due to the high DC output voltage, especially for cases with long power transmission lines.

In this paper, DC voltage deviation is eliminated and current sharing accuracy is enhanced by adding two compensation controllers to the reference value of each DC voltage. Meanwhile, the communication data of the compensation controllers are transferred from two adjacent converters through an LBC network. These controllers are achieved locally and it can achieve decentralized control. At the same time, the load current can achieve proportional sharing by compensation controller II. Then the current flow of the sharing system is modified by the outer control loop. Finally, the sharing of the DC output current is enhanced. The output voltage reference value of each converter can be obtained as:

$$v_{dci} = v_{dc}^* - \frac{m_0}{k_i} \cdot i_{dci} \cdot G_{LPF}$$

$$+G_{piv} \cdot \left( v_{dc}^* - \frac{v_{dc(i-1)} + v_{dc(i+1)}}{2} \cdot G_d \right)$$

$$-G_{pic} \cdot \left( \frac{i_{dci}}{k_i} - \frac{i_{dc(i-1)} + i_{dc(i+1)}}{2} \cdot G_d \right)$$

Compensation controller

where  $G_{LPF}$  is the low pass filter, and the cutting frequency  $f_c$  is set to 20 Hz.  $v_{dc(i-1)}$ ,  $v_{dc(i+1)}$ ,  $i_{dc(i-1)}$  and  $i_{dc(i+1)}$  are the DC side output voltage and current of the converters  $\#(i-1)$  and  $\#(i+1)$ .  $G_{piv}$  and  $G_{pic}$  are the transfer functions of the compensate voltage and current PI controllers, and the communication delay is shown as  $G_d$ , which can be expressed as follows:

$$G_d = \frac{1}{1 + \tau s} \quad (14)$$

The conventional droop curve and the modified droop curve are drawn based on eq. (13) in Fig. 4. The actual operating points, i.e.,  $v_{dci}$  and  $i_{dci}$ , are obtained when the system is in the steady state. After the compensating controllers are activated, the updated operating point is shown on the same figure of the droop curve.

In Fig. 4, the area with red shadowing is the voltage variation range with the traditional and the modified droop

controls. The variable  $\Delta v$  is determined by the compensating voltage controller and the optimal current sharing controller in eq. (13).

### B. Impact of the MT-HVDC System Parameters on Stability

In order to ensure the stability of the control system, the effect of changing the parameters of the power cable and communication delay is necessary. Substituting (7) and (11) into (13) yields:

$$[k_1(Y_{21} + Y_{31})G_d G_{pic} - 2Y_{11}(G_{pic} + m_0 G_{LPF}) - 2k_1] \frac{v_{dc1}}{v_{dc}^*} + [k_1(Y_{22} + Y_{32})G_{pic} G_d - 2Y_{12}(G_{pic} + m_0 G_{LPF}) - k_1 G_{piv} G_d] \frac{v_{dc2}}{v_{dc}^*} \quad (15a)$$

$$+ [k_1(Y_{23} + Y_{33})G_{pic} G_d - 2Y_{13}(G_{pic} + m_0 G_{LPF}) - k_1 G_{piv} G_d] \frac{v_{dc3}}{v_{dc}^*} = -2k_1(1 + G_{piv})$$

$$[k_2(Y_{11} + Y_{31})G_{pic} G_d - 2Y_{21}(G_{pic} + m_0 G_{LPF}) - k_2 G_{piv} G_d] \frac{v_{dc1}}{v_{dc}^*} + [k_2(Y_{12} + Y_{32})G_d G_{pic} - 2Y_{22}(G_{pic} + m_0 G_{LPF}) - 2k_2] \frac{v_{dc2}}{v_{dc}^*} \quad (15b)$$

$$+ [k_2(Y_{13} + Y_{33})G_{pic} G_d - 2Y_{23}(G_{pic} + m_0 G_{LPF}) - k_2 G_{piv} G_d] \frac{v_{dc3}}{v_{dc}^*} = -2k_2(1 + G_{piv})$$

$$[k_3(Y_{11} + Y_{21})G_{pic} G_d - 2Y_{31}(G_{pic} + m_0 G_{LPF}) - k_3 G_{piv} G_d] \frac{v_{dc1}}{v_{dc}^*} + [k_3(Y_{12} + Y_{22})G_{pic} G_d - 2Y_{32}(G_{pic} + m_0 G_{LPF}) - k_3 G_{piv} G_d] \frac{v_{dc2}}{v_{dc}^*} \quad (15c)$$

$$+ [k_3(Y_{13} + Y_{23})G_d G_{pic} - 2Y_{33}(G_{pic} + m_0 G_{LPF}) - 2k_3] \frac{v_{dc3}}{v_{dc}^*} = -2k_3(1 + G_{piv})$$

where  $Y_{ij}$  ( $i, j=1,2,3$ ) represents the element of the incidence matrix  $\mathbf{Y}_R$  and  $\mathbf{Y}_M$ .

Based on the aforementioned theoretical derivation and analysis, combining (15a) - (15c), the closed-loop transfer function  $v_{dci}/v_{dc}^*$  can be obtained. The stability of a MT-HVDC system with radial and meshed configurations can be tested by analyzing the closed-loop poles of the characteristic equation while varying the parameters of the transmission line and communication delay. Taking the control diagram of an arbitrary converter  $\#i$  ( $i=1, 2, 3$ ) as an example, the closed-loop dominant poles for the radial configuration are shown in Fig. 4.

It should be noted that the DC transmission line capacitance affects the twelve dominant poles of the closed-loop system in Fig. 5(a). When increasing the capacitance from 0.2  $\mu\text{F}/\text{km}$  to 0.6  $\mu\text{F}/\text{km}$ , the eight dominant poles are forced to move following the traces I ~ VIII, and the other four poles are kept in the same position on the left half of the s-plane. The black arrows indicate the movement of the poles due to such variations. Traces I, II, V, VI, VII and VIII gradually move towards the imaginary axis. Among the different traces, Trace V and VI are closer to the imaginary




Fig. 5. Closed-loop dominant poles for varying parameters of the radial configuration.

axis, which challenges the system stability. Traces III and IV move away from the imaginary axis.  $P_1 \sim P_4$  are kept in the same position on the left half of the plane. Hence, these dominant poles do not have a significant impact on the stability of the control system.

The transmission line inductance was changed from 0.3mH/km to 0.7mH/km, and the traces of the most critical dominant poles are zoomed in Fig. 5(b). Traces I ~ VIII are similar to the case of the capacitance. Among these traces, the critical traces V and VI are closer to the imaginary axis, and traces VII and VIII move faster toward the imaginary axis than in the case of the capacitance. However, there are no poles beyond the imaginary axis on the right half of the s-plane. However, the transmission line inductance becomes as large as 0.7mH/km. Traces IX and X move away from the imaginary axis.  $P_3$  and  $P_4$  are kept in the same position. Therefore, system stability can be ensured.

As shown in Fig. 5(c), it can be seen that traces I, II, VII and VIII also move slowly toward the imaginary axis when the resistance is changed from 0.03  $\Omega$ /km to 0.07  $\Omega$ /km, while traces V, VI and XI are closer to the imaginary axis, which challenges the system stability. The trend of traces III, IV, IX, X and XII are opposite the other traces, and they gradually move away from the imaginary axis. In this case,  $P_3$  and  $P_4$  are also located on the left side of the real axis, while




Fig. 6. Closed-loop dominant poles for varying parameters of the meshed configuration.

these two poles move toward the imaginary axis.

Fig. 5(d) shows the location of the dominant closed-loop poles while varying the communication delay from 1 s to 10 s. In this case,  $P_1 - P_6$  remain on the left side of the s plane and is keep at the same position. This is are different from the above three cases. Traces IX and X move away from the imaginary axis, which has little effect on the system stability. When traces XI and XII move towards the imaginary axis, the stability of the control system cannot be guaranteed when the LBC delay is too large.

A stability analysis of a MT-HVDC system with the meshed configuration is shown in Fig. 6. There are only four closed-loop dominant poles, which is different from the radial configuration. Fig. 6(a) shows that poles 1, 2, 3 and 4 are located on the left side of the imaginary axis and do not move. Although the DC cable capacitance is increased to 0.6  $\mu$ F/km, it does not have an impact on the control system stability.

Fig. 6(b) shows the effect of the inductance.  $P_1$  and  $P_2$  move toward the imaginary axis, and the terminating points of these traces are far from the imaginary axis.  $P_3$  and  $P_4$  are the same as the case of the capacitance. As observed, the dominant poles do not move much and they are still located on the left half of the s plane. Therefore, the system is stable when the DC cable inductance varies.

The closed-loop dominant poles for different cable resistance are shown in Fig. 6(c). When the values of the other parameters are fixed, the value of the resistance varies from 0.03  $\Omega$ /km to 0.07  $\Omega$ /km. All of the traces moves towards the imaginary axis except trace IV, which is different from the cases of the capacitance and the inductance. However, although the resistance becomes as large as 0.07  $\Omega$ /km, traces I ~ III are also located on the left half of the s plane. Hence, the system stability can be guaranteed for different line resistances in a reasonable range.

The closed-loop dominant poles of  $v_{dci}/v_{dc}^*$  for different LBC delays are shown in Fig. 6(d), where traces I and II




Fig. 7. Optimal current proportional sharing accuracy diagram based on modified droop control.

move toward the left half side of the real axis. Trace III moves away from the imaginary axis, while Trace IV moves toward it and is closer to the imaginary axis. From the above descriptions of the traces, it can be seen that a large communication delay leads to control system instability. The LBC delay is an important factor in the stability of the control system.

### C. Power Line Loss Optimization

To improve the overall efficiency of the system, an optimal current sharing strategy is proposed in this section to minimize the total power loss in the network. The proposed strategy includes two steps: In the first step, an optimization model is built to determine the voltages of the DC terminals with the objective of power loss minimization; in the second step, based on the optimal DC voltages, the load current sharing accuracies  $k_1: k_2: k_3$  can be obtained according to (15).

Optimization models are built for the different network topologies. Taking the MT-HVDC system with three DC terminals as an example, all three of the DC terminals are used to feed the load at the point of common coupling (PCC). The optimization formulations for the radial and meshed networks are expressed as (16) and (17), respectively.

1) *Radial Network*: In the radial configuration,  $v_{dc_iL}$  is the voltage across power cable between converter # $i$  and the load.  $R_{iL}$  is the resistance of the line between the # $i$  DC terminal and the load.

$$\lambda_1 = \min_{v_{dc_i}} P_{\text{loss\_radial}} = v_{dc1L}^2/R_{1L} + v_{dc2L}^2/R_{2L} + v_{dc3L}^2/R_{3L}$$

$$s.t. \quad V_{dc\min} \leq v_{dc_i} \leq V_{dc\max}, \quad i \in N$$

$$V_{L\min} \leq v_L \leq V_{L\max}; P_{MPP} > P_{dc_i}$$

$$v_{dc1L} > 0; v_{dc2L} > 0; v_{dc3L} > 0$$

$$v_{dc1L} = v_{dc1} - v_L; \quad v_{dc2L} = v_{dc2} - v_L; \quad v_{dc3L} = v_{dc3} - v_L$$

$$v_L = \left( \frac{v_{dc1} - v_L}{R_{1L}} + \frac{v_{dc2} - v_L}{R_{2L}} + \frac{v_{dc3} - v_L}{R_{3L}} \right) R_L \quad (16)$$

2) *Meshed Network*: In the meshed configuration,  $v_{dcL1}$  and  $v_{dcL3}$  are the voltages across the power cable between converter #1 (#3) and the load,  $v_{dc12}$  and  $v_{dc23}$  are the voltage across the power cable connecting converters #1, #2 and #3.  $R_{L1}$  and  $R_{L3}$  are the equivalent resistances of the land cables between converter #1 (#3) and the load.  $R_{12}$  and  $R_{23}$  are the equivalent resistance of the submarine cables between converter #1 (#3) and converter #2.

$$\lambda_2 = \min_{v_{dc_i}} P_{\text{loss\_mesh}} = \frac{v_{dcL1}^2}{R_{L1}} + \frac{v_{dc12}^2}{R_{12}} + \frac{v_{dc23}^2}{R_{23}} + \frac{v_{dcL3}^2}{R_{L3}}$$

$$s.t. \quad V_{dc\min} \leq v_{dc_i} \leq V_{dc\max}, \quad i \in N$$

$$V_{L\min} \leq v_L \leq V_{L\max}; P_{MPP} > P_{dc_i}$$

$$v_{dcL1} > 0; v_{dc12} > 0; v_{dc23} > 0; v_{dcL3} > 0$$

$$v_{dcL1} = v_{dc1} - v_L; \quad v_{dc12} = v_{dc2} - v_{dc1}$$

$$v_{dc1L} = v_{dc2} - v_{dc3}; \quad v_{dcL3} = v_{dc3} - v_L$$

$$v_L = \left( \frac{v_{dc1} - v_L}{R_{L1}} + \frac{v_{dc3} - v_L}{R_{L3}} \right) R_L \quad (17)$$

where  $\lambda_1$  and  $\lambda_2$  are the total power losses in transmission line with radial and meshed configuration, respectively.  $R_L$  is the load resistance,  $V_{L\max}$  and  $V_{L\min}$  are the upper and lower limits of the load voltage,  $V_{dc\min}$  and  $V_{dc\max}$  are the minimum and maximum DC voltages of the DC terminal # $i$ .  $N$  is the set of DC terminals.  $P_{MPP}$  is the maximum wind power.  $P_{dc_i}$  is the DC output power in each converter. Since the output power of a wind turbines should be no more than the maximum power point (MPP), the constraint  $P_{MPP} \geq P_{dc_i}$  need to be considered in the formulated optimization. This constraint can be used to ensure that the output power of the wind turbine does not violate its upper limit.

It should be noted that this optimization is a decentralized approach which is performed locally without any centralized controllers. The above optimization models can be solved using the MATLAB optimization toolbox [23].

Based on the obtained voltages at the DC terminals, the

TABLE I  
BASIC PARAMETERS OF THE SYSTEM

System Parameters		
Reference value of DC output voltage	$v_{dc}^*$	$\pm 150$ kV
Load resistance	$R_L$	30 $\Omega$
DC side capacitance	$C_{dc}$	250 $\mu$ F
Droop coefficient	$m_0$	3
LPF cut off frequency	$f_c$	20 Hz
LBC delay	$\tau$	1 s & 2 s
Compensate Controller Parameters		
Voltage Loop		Current Loop
$k_{pv}=0.1$	$k_{iv}=10$	$k_{pc}=0.1$
		$k_{ic}=524$

TABLE II  
DC CABLE PARAMETERS

	Radial			Meshed		
	$l_{1L}$	$l_{2L}$	$l_{3L}$	$l_{12}$	$l_{23}$	$l_{L1}$
Cable length(km)	$l_{1L}$	$l_{2L}$	$l_{3L}$	$l_{12}$	$l_{23}$	$l_{L1}$
Cable type	Land	Land	Land	Submarine	Land	Land
Power rating (MW)	250	250	250	250	250	250
Resistance ( $r_L/\Omega/\text{km}$ )	0.0367	0.0367	0.0367	0.0366	0.0367	0.0367
Inductance ( $l_L/\text{mH}/\text{km}$ )	0.349	0.349	0.349	0.414	0.349	0.349
Capacitance ( $c_L/\mu\text{F}/\text{km}$ )	0.21	0.21	0.21	0.17	0.21	0.21


current sharing proportions  $k_1$ ,  $k_2$  and  $k_3$  can be calculated by (15). The proposed control strategy with optimal current sharing accuracy is depicted in Fig. 7. It can be seen that the optimization module generates the objective load current sharing proportion, i.e.  $k_1$ ,  $k_2$  and  $k_3$ . Then, a control diagram with the modified droop control method is employed to ensure the required output current.

#### IV. SIMULATION RESULTS


In order to verify the proposed control method for a MT-HVDC transmission system, MATLAB/Simulink is used as the simulation environment to implement the advanced droop control method with both the radial and meshed configurations. The MT-HVDC system parameters are summarized in Table I. The DC cable parameters are listed in Table II.

##### A. Simulation Results of the Radial Configuration MT-HVDC

The purpose of the simulation is to verify the stability of the proposed control system and to test the responses for the voltage restoration and the optimized current proportional sharing accuracy. In Fig. 8, it can be seen that the compensating controllers are activated at  $t = 2$  s. Before  $t = 2$  s, the current proportional sharing accuracy is unable to meet the optimal power line loss requirement. After  $t = 2$  s, the DC output current of each converter is gradually changed, which matches the optimal current proportional sharing accuracy  $k_1:k_2:k_3 \approx 0.79:1:0.66$ .



(a)  $l_{1L}=100$  km,  $l_{2L}=80$  km,  $l_{3L}=120$  km,  $\tau=1$  s.



(b)  $l_{1L}=100$  km,  $l_{2L}=80$  km,  $l_{3L}=120$  km,  $\tau=2$  s.

Fig. 8. Transient response for voltage restoration and current sharing accuracy in radial configuration.

Meanwhile, the DC side average voltage is increased by 2.88 kV and it is closer to the reference of each converter DC-link voltage. When the cable length is fixed ( $l_{1L}=100$  km,  $l_{2L}=80$  km,  $l_{3L}=120$  km), the communication delay is changed from  $\tau=1$  s to  $\tau=2$  s as shown in Fig. 8(a) and (b). These two cases have different adjusted times, 3 s and 6 s are needed to achieve stability, respectively. The other performance indexes are unchanged for the two cases.

In Fig. 9, the cable length is increased to  $l_{1L}=150$  km,  $l_{2L}=130$  km and  $l_{3L}=170$  km, respectively. By comparing the results in Fig. 9 (a) with (b), it can be seen that an increasing communication delay  $\tau$  results in a longer transient time. However, there is only a very short oscillation and the whole system reaches the steady state quickly. The optimal current proportional sharing accuracy is  $k_1:k_2:k_3 \approx 0.82:1:0.73$  which is changed with the increase of the cable length. In this case,



(a)  $l_{1L}=150$  km,  $l_{2L}=130$  km,  $l_{3L}=170$  km,  $\tau=1$  s.(b)  $l_{1L}=150$  km,  $l_{2L}=130$  km,  $l_{3L}=170$  km,  $\tau=2$  s.

Fig. 9. Transient response for voltage restoration and current sharing accuracy in radial configuration.

the average voltage of the three converters DC side is increased by 2.83 kV after the compensating controller is activated at  $t = 2$  s. The transient time duration is the same as Fig. 8 (a) and (b). The DC output voltage of the converters matches the optimization design.

### B. Simulation Results of the Meshed Configuration MT-HVDC

The voltage restoration and current sharing accuracy transient responses for the meshed configuration are shown in Fig. 10. The DC output current of each converter is gradually adjusted, which matches the optimal current proportional sharing accuracy  $k_1:k_2:k_3 \approx 1:0.05:0.74$ . Meanwhile, the DC side average voltage is increased by 2.54 kV and it is higher than the rated value.

However, the maximum deviation is less than 5% of the rated value. When the DC cable length is fixed ( $l_{1L}=100$  km,



(a)  $l_{1L}=100$  km,  $l_{12}=70$  km,  $l_{23}=60$  km,  $l_{L3}=120$  km,  $\tau=1$  s.(b)  $l_{1L}=100$  km,  $l_{12}=70$  km,  $l_{23}=60$  km,  $l_{L3}=120$  km,  $\tau=2$  s.

Fig. 10. Transient response for voltage restoration and current sharing accuracy in meshed configuration.

$l_{12}=70$  km,  $l_{23}=60$  km and  $l_{L3}=120$  km), the communication delay is changed from  $\tau=1$  s to  $\tau=2$  s as shown in Fig. 10 (a) and (b). The transient times are 2s and 4s, respectively. In the meshed configuration, the transient time is shorter than that in the radial configuration.


In Fig. 11, the DC output average voltage deviation is increased from 2.54 kV to 5.32 kV when the DC cable length is increased. However, the average voltage size is also kept in the safe range of the converter output voltage.

The actual DC output current is proportional among the three converters and matches the theoretical value ( $k_1:k_2:k_3 \approx 1:0.03:0.88$ ) of the current proportional sharing accuracy according to the optimal power line loss. Meanwhile, after starting compensating control at  $t=2$  s, the whole control system needs two LBC sampling periods to meet the steady state in different time delays. In this paper, the meshed configuration was chosen and the middle of the




TABLE III  
OPTIMAL CURRENT SHARING AND MINIMIZATION POWER LINE LOSS IN DIFFERENT CASE

		Radial configuration		Meshed configuration	
DC cable Length (km)		$l_{1L}=100; l_{2L}=80; l_{3L}=120$	$l_{1L}=150; l_{2L}=130; l_{3L}=170$	$l_{L1}=100; l_{L3}=120; l_{12}=70; l_{12}=60$	$l_{L1}=150; l_{L3}=170; l_{12}=120; l_{12}=110$
Optimal current sharing ( $k_{opt1}:k_{opt2}:k_{opt3}$ )		0.8:1:0.68	0.82:1:0.73	1:0.05:0.74	1:0.03:0.88
Power line loss minimization (kW)	Without Proposed strategy	$1.3825 \times 10^5$	$1.5509 \times 10^5$	$1.5202 \times 10^5$	$1.7206 \times 10^5$
	With Proposed strategy	$2.9505 \times 10^4$	$4.3576 \times 10^4$	$4.5185 \times 10^4$	$6.5995 \times 10^4$



(a)  $l_{L1}=150$  km,  $l_{12}=120$  km,  $l_{23}=110$  km,  $l_{L3}=170$  km,  $\tau=1$  s.



(b)  $l_{L1}=150$  km,  $l_{12}=120$  km,  $l_{23}=110$  km,  $l_{L3}=170$  km,  $\tau=2$  s.

Fig. 11. Transient response for voltage restoration and current sharing accuracy in meshed configuration.

converter was not connected to the load directly. The starting procedure is determined by some factors in the system, e.g. the DC output voltage of two adjacent converters, the DC cable length, the lines impedance, etc.





Fig. 12 The photo of the VSC-MTDC system prototype.

This is more complicated than the radial configuration. By using the modified droop control method, expected results can be implemented. Based on the above analysis and calculation, the numerical percentage of the minimization power line loss with and without the proposed control strategy and the optimal current proportional sharing accuracy of both the radial and meshed configuration are shown in Table III.


### V. EXPERIMENTAL VALIDATION

A  $3 \times 10$  kW prototype with three converters is implemented to validate the proposed optimal current sharing proportion based on an improved droop control. A photo of the hardware is shown in Fig. 12. The reference of the DC output voltage is 380V, and the load resistance is 19Ω. The experimental results for the radial configuration are shown in Fig. 13.

The optimal current sharing proportion  $k_{opti} = 0.97:1:0.94$  can be calculated when the system power line loss is minimized. The experimental results are similar to the



(a) DC output current sharing.



(b) DC output voltage variation.

Fig. 13. The experimental results of transient response for radial configuration.


calculation value as shown in Fig. 13(a). At the same time, when the system is in the steady state, the average DC output voltage of all the converters is closed to 380V as shown in Fig. 13(b), which means that the DC output voltage is increased by 8.5V, and the maximum voltage error is 11.5V, which is kept under 5% of the reference voltage.

Experimental results for the mesh configuration are shown in Fig. 14 (a) and (b). The variation of the current sharing is not really obvious after adding the compensating current controller at  $t > 1$  s. In this case, the optimal current sharing proportion is similar to the traditional droop proportion coefficient.


When the compensating voltage controller is activated at 1 s, the average value of the DC output voltage is increased by 2 V. The corresponding maximum output voltage error is smaller than that in the radial configuration. According to the above analysis, the mesh configuration has some advantages, e.g. current sharing accuracy and voltage regulating capability.

## VI. CONCLUSIONS

The modified voltage-current type droop control scheme presented in this paper combines the advantages of an increased average DC output voltage and decentralized



(a) DC output current sharing.



(b) DC output voltage variation.

Fig. 14. The experimental results of transient response for mesh configuration.

optimal current proportional sharing accuracy for power line loss minimization in MT-HVDC systems. The key points are summarized as follows:

(1) Simplified models of the different networks in MT-HVDC systems are presented by cascading several identical pi-sections, and the relationship between the DC output current and voltage for converters # 1~ # 3 are obtained.

(2) The decentralized control method is implemented using the data of two adjacent converters, which reduces the stress of the low bandwidth communication system.

(3) The stability of the control system is ensured by observing the tendency of the closed-loop dominant poles while varying the DC cable transmission line impedance parameters and the communication delay time, respectively.

(4) Current sharing proportional accuracy is optimally allocated to minimize the power line loss with a proposed droop control method. Meanwhile, the DC output voltage average value can be restored and each voltage is guaranteed to be within the acceptable range.

## APPENDIX

The elements of the incidence matrix  $\mathbf{Y}_R = [Y_{11} \ Y_{12} \ Y_{13}; Y_{21} \ Y_{22} \ Y_{23}; Y_{31} \ Y_{32} \ Y_{33}]$  are given in (A1)-(A9).

$$Y_{11} = \frac{1}{\lambda} \left[ \begin{array}{l} l_{2L} l_{3L} (1 + s C_{dk} R_L + s l_{1L} l_{1C} C_{dk} + s^2 C_{dk} R_L l_{1L}^2 r_L c_L + s^2 l_{1L} l_{1C} C_{dk} \\ + s^3 C_{dk} R_L l_{1L}^2 r_L c_L) (r_L + s l_L)^2 + R_L (l_{3L} + l_{2L} + s l_{2L}^2 r_L c_L + s^2 l_{2L}^2 \delta_3 r_L c_L) \\ + s^2 l_{2L}^2 r_L c_L + s^2 l_{2L}^2 r_L c_L (1 + s l_{1L} l_{1C} C_{dk} + s^2 l_{1L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A1)$$

$$Y_{12} = \frac{1}{\lambda} \left[ \begin{array}{l} s l_{2L} l_{3L} C_{dk} R_L (1 + s l_{2L}^2 r_L c_L + s^2 l_{2L}^2 r_L c_L) (r_L + s l_L)^2 \\ - (1 + s l_{2L} l_{1C} C_{dk} + s^2 l_{2L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A2)$$

$$Y_{13} = \frac{1}{\lambda} \left[ \begin{array}{l} s l_{2L} l_{3L} C_{dk} R_L (1 + s l_{2L}^2 r_L c_L + s^2 l_{2L}^2 r_L c_L) (r_L + s l_L)^2 \\ - (1 + s l_{2L} l_{1C} C_{dk} + s^2 l_{2L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A3)$$

$$Y_{21} = \frac{1}{\lambda} \left[ \begin{array}{l} s l_{1L} l_{3L} C_{dk} R_L (1 + s l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L) (r_L + s l_L)^2 \\ - (1 + s l_{1L} l_{1C} C_{dk} + s^2 l_{1L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A4)$$

$$Y_{22} = \frac{1}{\lambda} \left[ \begin{array}{l} l_{1L} l_{2L} (1 + s C_{dk} R_L + s l_{1L} l_{1C} C_{dk} + s^2 C_{dk} R_L l_{1L}^2 r_L c_L + s^2 l_{1L} l_{1C} C_{dk} \\ + s^3 C_{dk} R_L l_{1L}^2 r_L c_L) (r_L + s l_L)^2 + R_L (l_{3L} + l_{1L} + s l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L) \\ + s^2 l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L (1 + s l_{2L} l_{1C} C_{dk} + s^2 l_{2L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A5)$$

$$Y_{23} = \frac{1}{\lambda} \left[ \begin{array}{l} s l_{1L} l_{3L} C_{dk} R_L (1 + s l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L) (r_L + s l_L)^2 \\ - (1 + s l_{1L} l_{1C} C_{dk} + s^2 l_{1L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A6)$$

$$Y_{31} = \frac{1}{\lambda} \left[ \begin{array}{l} s l_{1L} l_{2L} C_{dk} R_L (1 + s l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L) (r_L + s l_L)^2 \\ - (1 + s l_{1L} l_{1C} C_{dk} + s^2 l_{1L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A7)$$

$$Y_{32} = \frac{1}{\lambda} \left[ \begin{array}{l} s l_{1L} l_{2L} C_{dk} R_L (1 + s l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L) (r_L + s l_L)^2 \\ - (1 + s l_{1L} l_{1C} C_{dk} + s^2 l_{1L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A8)$$

$$Y_{33} = \frac{1}{\lambda} \left[ \begin{array}{l} l_{1L} l_{2L} (1 + s C_{dk} R_L + s l_{1L} l_{1C} C_{dk} + s^2 C_{dk} R_L l_{1L}^2 r_L c_L + s^2 l_{1L} l_{1C} C_{dk} \\ + s^3 C_{dk} R_L l_{1L}^2 r_L c_L) (r_L + s l_L)^2 + R_L (l_{2L} + l_{1L} + s l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L) \\ + s^2 l_{1L}^2 r_L c_L + s^2 l_{1L}^2 r_L c_L (1 + s l_{3L} l_{1C} C_{dk} + s^2 l_{3L} l_{1C} C_{dk}) (r_L + s l_L) \end{array} \right] \quad (A9)$$

where:

$$\lambda = \left( \begin{array}{l} [R_L r_L c_L l_{1L} l_{3L} (s + s^2) + R_L] l_{1L} l_{2L} \\ + [R_L r_L c_L l_{1L} l_{2L} (s + s^2) + R_L] l_{2L} l_{3L} \\ + [R_L r_L c_L l_{2L} l_{3L} (s + s^2) + R_L] l_{1L} l_{3L} \end{array} \right) (r_L + s l_L)^3$$

The elements of the incidence matrix  $Y_M = [Y_{11} Y_{12} Y_{13}; Y_{21} Y_{22} Y_{23}; Y_{31} Y_{32} Y_{33}]$  are given in (B1)-(B9).

$$Y_{11} = s C_{dk1} + \frac{1}{Z_{L1}} - Z_p Z_{13} / (Z_{L1} Z_p Z_{13} + Z_{L1}^2 Z_p^2 + Z_{L1}^2 Z_p^2) + \frac{Z_{L1}^2 Z_p^2 Z_{13}}{R_L} + s c_{13L} Z_{L1}^2 Z_p^2 Z_{13} \quad (B1)$$

$$Y_{12} = -Z_{13} / (Z_p Z_{L1} + Z_p Z_{13} + \frac{Z_{L1} Z_p Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p Z_{13} + Z_{L1} Z_{13}) \quad (B2)$$

$$Y_{13} = -Z_p / (Z_{L1} Z_{13} + Z_p Z_{13} + \frac{Z_{L1} Z_p Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p Z_{13} + Z_{L1} Z_p) \quad (B3)$$

$$Y_{21} = -Z_{13} / (Z_p Z_{L1} + Z_p Z_{13} + \frac{Z_{L1} Z_p Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p Z_{13} + Z_{L1} Z_{13}) \quad (B4)$$

$$Y_{22} = s C_{dk2} + \frac{1}{Z_p} - Z_{L1} Z_{13} / (Z_{L1} Z_p Z_{13} + Z_{L1}^2 Z_p^2 + Z_{L1}^2 Z_p^2) + \frac{Z_{L1}^2 Z_p^2 Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p^2 Z_{13} \quad (B5)$$

$$Y_{23} = -Z_{L1} / (Z_p Z_{L1} + Z_p Z_{13} + \frac{Z_{L1} Z_p Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p Z_{13} + Z_{L1} Z_{13}) \quad (B6)$$

$$Y_{31} = -Z_p / (Z_{L1} Z_{13} + Z_p Z_{13} + \frac{Z_{L1} Z_p Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p Z_{13} + Z_{L1} Z_p) \quad (B7)$$

$$Y_{32} = -Z_{L1} / (Z_p Z_{L1} + Z_p Z_{13} + \frac{Z_{L1} Z_p Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p Z_{13} + Z_{L1} Z_{13}) \quad (B8)$$

$$Y_{33} = s C_{dk3} + \frac{1}{Z_{L3}} - Z_{L1} Z_p / (Z_{L1} Z_p Z_{13} + Z_{L1}^2 Z_p^2 + Z_{L1}^2 Z_p^2) + \frac{Z_{L1} Z_p^2 Z_{13}}{R_L} + s c_{13L} Z_{L1} Z_p^2 Z_{13} \quad (B9)$$

Where  $Z_{L1} = l_{1L} (r_L + s l_L)$ ,  $Z_{L2} = l_{2L} (r_L + s l_L)$ ,  $Z_{L3} = l_{3L} (r_L + s l_L)$ ,

$Z_p = (Z_{L1} + Z_{L2}) / (Z_{L3} + Z_{L3})$

## ACKNOWLEDGMENT

This work was supported by the Fundamental Research Funds for the Central Universities (DL09CB05).

## REFERENCES

- [1] K. Rouzbehi, A. Miranian, A. Luna, and P. Rodriguez, "DC voltage control and power sharing in multiterminal DC grids based on optimal DC power flow and voltage-droop strategy," *IEEE J. Emerg. Sel. Topics Power Electron.*, Vol. 2, No. 4, pp.1171-1180, Dec. 2014.
- [2] Z. Wei, Y. Yuan, X. Lei, H. Wang, G. Sun, and Y. Sun, "Direct-current predictive control strategy for inhibiting commutation failure in HVDC converter," in *IEEE Trans. Power Syst.*, Vol. 29, No. 5, pp. 2409-2417, Sep. 2014.
- [3] X. Shi, Z. Wang, B. Liu, Y. Liu, L. M. Tolbert, and F. Wang, "Characteristic investigation and control of a modular multilevel converter-based HVDC system under single-line-to-ground fault conditions," in *IEEE Trans. Power Electron.*, Vol. 30, No. 1, pp. 408-421, Jan. 2015.
- [4] T. M. Haileselassie and K. Uhlen, "Impact of DC line voltage drops on power flow of MTDC using droop control," *IEEE Trans. Power Syst.*, Vol. 27, No. 3, pp. 1441-1449, Aug. 2012.
- [5] B. Sfurto, R. da Silva, and S. Chaudhary, "A MTDC system layout review based on system revenue a Kriegers Flak case study," *Power Engineering, Energy and Electrical Drives (POWERENG), 2013 Fourth International Conference on*, Istanbul, pp. 793-800, 2013.
- [6] F. Deng and C. Z. Zhe, "An off-shore wind farm with DC grid connection and its performance under power system transients," *2011 IEEE Power and Energy Society General Meeting*, pp. 24-29, 2011.
- [7] C. Li, P. Zhan, J. Wen, M. Yao, N. Li, and W. J. Lee, "Offshore wind farm integration and frequency support control utilizing hybrid multiterminal HVDC transmission," *IEEE Trans. Ind. Appl.*, Vol. 50, No. 4, pp. 2788-2797, Jul./Aug. 2014.
- [8] J. Ren, K. Li, L. Sun, J. Zhao, Y. Liang, W. Lee, Z. Ding, and Y. Sun, "A coordination control strategy of voltage source converter based MTDC for off-shore wind farms," *IEEE Industry Applications Society Annual Meeting*, pp. 5-9, 2014.
- [9] S. J. Shao and V. G. Agelidis, "Review of DC system technologies for large scale integration of wind energy systems with electricity grids," *Energies*, Vol. 3, No. 6, pp. 1303-1319, Jun. 2010.
- [10] S. Rodrigues, R.T. Pinto, P. Bauer, and J. Pierik, "Optimal power flow control of VSC-based multiterminal DC network for off-shore wind integration in the north sea," *IEEE J. Emerg. Sel. Topics Power Electron.*, Vol. 1, No. 4, pp.260-268, Dec. 2013.
- [11] L. Wang and M. S.-N. Thi, "Power flow control of off-shore wind farms fed to power grids using an HVDC system," *2012 IEEE Industry Applications Society Annual Meeting (IAS)*, pp.7-11, 2012.
- [12] X. Sun, Y.S. Lee, and D. H. Xu, "Modeling, analysis, and implementation of parallel multi-inverter systems with instantaneous average-current-sharing scheme," *IEEE Trans. Power Electron.*, Vol. 18, No. 3, pp. 844-856, May. 2003.
- [13] X. N. Lu, J. M. Guerrero, K. Sun, J. C. Vasquez, R. Teodorescu, and L. P. Huang. "Hierarchical control of

parallel AC-DC converter interfaces for hybrid microgrids,” *IEEE Trans. Smart Grid*, Vol. 5, No. 2, pp. 683-692, Mar. 2014.

- [14] W. Wang and M. Barnes, “Power flow algorithms for multi-terminal VSC-HVDC with droop control,” *IEEE Trans. Power Syst.*, Vol. 29, No. 4, pp.1721-1730, Jul. 2014.
- [15] X. N. Lu, J. M. Guerrero, K. Sun, and J. C. Vasquez, “An improved droop control method for DC microgrids based on low bandwidth communication with DC bus voltage restoration and enhanced current sharing accuracy,” *IEEE Trans. Power Electron.*, Vol. 29, No. 4, pp.1800-1812, Apr. 2014.
- [16] Y. Q. Liu, J. Z. Wang, N. N. Li, Y. Fu, and Y. C. Ji, “Enhanced load power sharing accuracy in droop-controlled DC microgrids with both mesh and radial configurations,” *Energies*, Vol. 8, No. 5, pp. 3591-3605, Apr. 2015.
- [17] J. Beerten, S. Cole, and R. Belmans, “Modeling of multi-terminal VSC HVDC systems with distributed DC voltage control,” *IEEE Trans. Power Syst.*, Vol. 29, No.1, pp.34-42, Jan. 2014.
- [18] G. O. Kalcon, G. P. Adam, O. Anaya-Lara, S. Lo, and K. Uhlen, “Small-signal stability analysis of multi-terminal VSC-based DC transmission systems,” *IEEE Trans. Power Syst.*, Vol. 27, No. 4, pp. 1818-1830, Nov. 2012.
- [19] R. T. Pinto, P. Bauer, S. F. Rodrigues, E. J. Wiggelinkhuizen, J. Pierik, and B. Ferreira, “A novel distributed direct-voltage control strategy for grid integration of off-shore wind energy systems through MTDC network,” *IEEE Trans. Ind. Electron.*, Vol. 60, No. 6, pp. 2429-2441, Jun. 2013.
- [20] S. Lin and C. Yeh, “Microstrip branch-line coupler with optimized spurious suppression based on cascaded PI-type equivalent transmission lines,” *2014 IEEE International Workshop on Electromagnetics*, pp. 4-6, 2014.
- [21] *An Introduction to High Voltage Direct Current (HVDC) Underground Cable*, Europacable, Brussels, 2011
- [22] K. Rouzbehi, A. Miranian, J. I. Candela, A. Luna, and P. Rodriguez, “A generalized voltage droop strategy for control of multiterminal DC grids,” *IEEE Trans. Ind. Appl.*, Vol. 51, No. 1, pp. 607-618, Jan. 2015.
- [23] A.-P. Mónica, E.-À. Agustí, G.-A. Samuel, and G.-B. Oriol, “Droop control for loss minimization in HVDC multi-terminal transmission systems for large off-shore wind farms,” *Electric Power Systems Research*, Vol. 112, No. 1, pp. 48-55, Apr. 2014.




**Yiqi Liu** received his B.S. degree in Electrical Engineering from the Northeast Agriculture University, Harbin, China, in 2009; and his M.S. degree in Electrical Engineering from the Tianjin University of Technology, Tianjin, China, in 2012. He is presently working towards his Ph.D. degree in the School of Electrical Engineering and

Automation, Harbin Institute of Technology, Harbin, China. From 2013 to 2015, he was a Visiting Ph.D. student with the Center for Ultra-Wide-Area Resilient Electric Energy Transmission Networks (CURENT), University of Tennessee, Knoxville, TN, USA, with support from China Scholarship Council. He joined the Northeast Forestry University, Harbin, China, in 2016, and is presently working as an Associate

Professor. His current research interests include power electronics for renewable energy sources, multilevel converters, high-voltage direct-current (HVDC) technology, DC micro-grids and energy conversion.



**Wenlong Song** received his B.S., M.S., and Ph.D. degrees in Electrical Engineering from the Northeast Forestry University, Harbin, China, in 1995, 2004, and 2008, respectively. He joined the Northeast Forestry University, in 1995, and is presently working as a full Professor. His current research interests include forestry engineering automation, plant life information detection, automation control technology, etc.



**Ningning Li** received his B.S. and M.S. degrees in Electronics Engineering from the Northeast Agriculture University, Harbin, China, in 2005 and 2010, respectively; and his Ph.D. degree in Electrical Engineering from the Harbin Institute of Technology, Harbin, China, in 2016. He joined the Northeast Agricultural University, in 2016, and is presently working as a Lecturer. His current research interests include power electronics and drives, renewable energy generation and applications, FACTS, and power quality.



**Linquan Bai** received his B.S. and M.S. degrees in Electrical Engineering both from Tianjin University, China in 2010 and 2013 respectively. He is working towards his Ph.D. degree at the University of Tennessee, Knoxville, USA. His research interests include electricity markets, microgrid optimal operation and planning, and integrated energy systems.



**Yanchao Ji** received the B.S. and M.S. degrees in electrical engineering from Northeast Dianli University, Jilin, China, in 1983 and 1989, respectively, and the Ph.D. degree in electrical engineering from the North China Electric Power University, Beijing, China, in 1993. He joined the Department of Electrical Engineering, Harbin Institute of Technology, Harbin, China, in 1993. From 1995 to 1996, he was an Associate Professor with the Department of Electrical Engineering, Harbin Institute of Technology, where he is currently a Professor. His current research interests include pulse width modulation technique, power converter, and flexible ac transmission systems device.